

COUNTY LOCAL LAWS

UNSAFE PLUMBING AND GAS FITTING CONDITIONS.

23-2 SCOPE

THE PROVISIONS OF THIS TITLE SHALL APPLY TO AND GOVERN PLUMBING AND GAS FITTING AS DEFINED HEREIN.

23-3 DEFINITIONS

ON-SITE: WATER, SEWER AND STORM DRAIN SYSTEMS.

A PRIVATE WATER DISTRIBUTION, SANITARY SEWER OR STORM DRAIN SYSTEM OF WATER MAINS, VALVES, FIRE HYDRANTS, SEWER PIPES, MANHOLES; CATCH BASINS, STORM DRAIN PIPE, AND THEIR APPURTENANCES, OWNED AND MAINTAINED BY A PRIVATE INTEREST TO SERVE TWO OR MORE BUILDINGS WITHIN THE NON-SUB-DIVIDED INTEREST OF THE OWNER, WITH FINAL CONNECTIONS TO A PUBLIC WATER, SANITARY SEWER OR STORM DRAINAGE SYSTEM.

PLUMBING: THE DEFINITION SECTION AS SET FORTH IN CHAPTER 1 OF THE 1971 NATIONAL STANDARD PLUMBING CODE IS HEREBY ADOPTED AND INCORPORATED BY REFERENCE THERETO AS IF FULLY SET FORTH HEREIN.

GAS FITTING:

APPLICABILITY:

THIS STANDARD APPLIES TO THE INSTALLATION OF NONINDUSTRIAL TYPE GAS APPLIANCES AND TO THE DESIGN, FABRICATION, INSTALLATION AND TESTS OF NONINDUSTRIAL PIPING SYSTEMS FOR FUEL GASES SUCH A NATURAL GAS, MANUFACTURED GAS, UNDILUTED LIQUEFIED PETROLEUM GASES, LIQUEFIED PETROLEUM GAS-AIR MIXTURES, OR MIXTURES OF ANY OF THESE GASES, AS FOLLOWS:

(A) LOW PRESSURE (NOT IN EXCESS OF 1/2 POUND PER SQUARE INCH OR 14 INCHES WATER COLUMN) PIPING SYSTEMS EXTENDING FROM THE OUTLET OF THE METER SET ASSEMBLY, OR THE OUTLET OF THE SERVICE REGULATOR WHEN A METER IS NOT PROVIDED, TO THE INLET CONNECTIONS OF APPLIANCES.

(B) THE INSTALLATION OF APPLIANCES SUPPLIED AT PRESSURES OF 1/2 POUND PER SQUARE INCH OR LESS.

NONAPPLICABILITY:

THIS STANDARD DOES NOT APPLY TO:

(A) GAS PIPING SYSTEMS FOR INDUSTRIAL INSTALLATIONS AT ANY PRESSURE OR ANY OTHER GAS PIPING SYSTEM OPERATING AT PRESSURES GREATER THAN 1/2 POUND PER SQUARE INCH. PIPING IN SUCH INSTALLATIONS SHALL BE